


**UK Type Examination Certificate CML 21UKEX3107 Issue 2****United Kingdom Conformity Assessment**

- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **HP Spartan LED Luminaire (for dust atmospheres)**
- 3 Manufacturer **Raytec Ltd**
- 4 Address **Unit 15 Wansbeck Business Park  
Rotary Parkway  
Ashington  
Northumberland  
NE63 8QW, UK**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:  
EN IEC 60079-0:2018                      EN 60079-31:2014

- 10 The equipment shall be marked with the following:



Ex tb IIIC T104°C Db

Ta = -50°C to +50°C





CML 21UKEX3107  
Issue 2

## 11 Description

The combined PSU and JB assembly consists of two separate dust protected enclosures, one containing LED Driver circuits and the other containing suitably certified Ex component terminals, for connection of internal and field wiring using suitably certified cable glands. The two enclosures are separated using a suitably certified bushing.

The above combined assembly is mounted to the dust protected LED compartment, with the wiring from the JB compartment connected to the LED assemblies.

The units have an environmental rating of IP 66.

A maximum of two cable entries can be supplied with each luminaire. Suitably certified cable entries may be various thread types up to a maximum diameter of 25 mm.

The equipment is also marked with an ingress protection rating of IP67. An ingress protection rating of IPX7 has not been verified under the CML certification.

An optional self-adhesive anti-static film can be fitted over the glass externally.

Operating voltage may be 150-264V AC/DC or 110V-264V AC/DC with a maximum wattage of 300W.

### Variation 1

This variation introduces the following modifications:

- i. Increase the flamepath gap on IIB variants from 0.1mm to 0.2mm
- ii. To update conditions of manufacture
- iii. To update the product description
- iv. To provide clarification on product specification on certification documents

### Variation 2

This variation introduces the following modifications:

- i. Minor changes to LED board

## 12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	26 Mar 2021	R13817A/00	Issue of prime certification
1	23 Jan 2023	R16084A/00	Issue of variation 1
2	24 May 2023	R16358A/00	Issue of variation 2

Note: Drawings that describe the equipment are listed or referred to in the Annex.



CML 21UKEX3107  
Issue 2

### 13 Conditions of Manufacture

- i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated.
- ii. The manufacturer shall fit only the certified Ex Components listed in the certification documentation and the manufacturer's instructions. All Special Conditions of Certification/ Special Conditions for Safe Use/ Schedule of Limitations shall be satisfied for each part fitted.
- iii. If the terminals or components are fitted with cables/wiring by the manufacturer; all cables/wires shall be suitable for rated voltage and current of each separate circuits and Ex Components to which they are connected.
- iv. The Line Bushing shall be suitable for a service temperature range of at least -50°C to +85°C.
- v. Where the LEDs are configured in a single string of 12 connected in series, only the XLamp LEDs are to be used.

### 14 Specific Conditions of Use

None.

## Certificate Annex

**Certificate Number** CML 21UKEX3107  
**Equipment** HP Spartan LED Luminaire (for dust atmospheres)  
**Manufacturer** Raytec Ltd



The following documents describe the equipment defined in this certificate:

### Issue 0

Drawing No	Sheets	Rev	Approved date	Title
1050-SD-0034	2 of 4	D	26 Mar 2021	SPARTAN HIGH POWER LED FLOODLIGHT/HIGHBAY
1050-SD-0034	4 of 4	D	26 Mar 2021	SPARTAN HIGH POWER LED FLOODLIGHT/HIGHBAY

### Issue 1

Drawing No	Sheets	Rev	Approved date	Title
1050-SD-00034	1 of 4	D	23 Jan 2023	Spartan High Power LED Floodlight/Highbay
1050-SD-00034	2 of 4	E	23 Jan 2023	Spartan High Power LED Floodlight/Highbay

### Issue 2

Drawing No	Sheets	Rev	Approved date	Title
1050-SD-00034	2 of 4	F	24 May 2023	SPARTAN HIGH POWER LED FLOODLIGHT/HIGHBAY
1050-SD-00034	3 of 4	E	24 May 2023	SPARTAN HIGH POWER LED FLOODLIGHT/HIGHBAY